



Product Service

# CERTIFICATE

No. B 13 05 26944 014

**Holder of Certificate: Tecnoelastic s.r.l.**Via Calabria 3/5  
35020 Saonara (Padova)  
ITALY**Certification Mark:****Product: Fluid level switches**

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.: SIC12185.04



Date, 2013-06-17

  
( Fabrizio Gasparella )

Page 1 of 3



Product Service

**CERTIFICATE**

**No. B 13 05 26944 014**

**Model(s):** Olympic 01, Olympic 03, Olympic 04, Fox G02, Fox G04, Fox G06, Supertec 01, Supertec 03, Flotec 01, Flotec 03, Taurus 01, Taurus 03, Taurus 04, Mouse 01, Mouse 02, Mouse 03

**Brand Name:** TECNOPLASTIC

**Parameters:**

Rated voltage:	See attachment
Rated frequency:	50-60 Hz
Rated input current:	See attachment
Rated max ambient temperature:	60°C
Protection class:	See attachment
Degree of protection:	IP68

**Tested according to:** EN 60730-1:2011  
EN 60730-2-15:2010

**Production Facility(ies):** 26944



Product Service



Product Service

Attachment to  
**CERTIFICATE**

**No. B 13 05 26944 014**

Models	Rated Voltage	Rated Input Current	Protection Class
Olympic 01	250 VAC	20(8) A	I
Olympic 03	250 VAC	10(8) A	I
Olympic 04	400 VAC	10(6) A	I
Fox G02	250 VAC	20(8) A	I
Fox G04	250 VAC	20(8) A	I
Fox G06	250 VAC	26(10) A	I
Supertec 01	250 VAC	20(8) A	I
Supertec 03	250 VAC	20(8) A	II
Flotec 01	250 VAC	20(8) A	I
Flotec 03	250 VAC	20(8) A	II
Taurus 01	250 VAC	20(8) A	I
Taurus 03	250 VAC	20(8) A	II
Taurus 04	250 VAC	20(8) A	I
Mouse 01	250 VAC	20(8) A	I
Mouse 02	250 VAC	26(10) A	I
Mouse 03	400 VAC	10(6) A	I

Date, 2013-06-17

Page 3 of 3



Product Service